

Missouri Department Of Natural Resources
Water Protection Program
Public Drinking Water Branch
P.O. Box 176
Jefferson City, MO 65102
(573)751-5331

Lead and Copper 90th Percentile Report

PWS Name : KIRKSVILLE
Mail to : KENNETH DUNLAP
WATER TREATMENT PLANT
201 S FRANKLIN ST
KIRKSVILLE MO 63501

PWS ID : MO2010429
County : ADAIR

Please notify us of any
name and address changes

Monitoring Period Start Date 1/1/2014
Monitoring Period End Date 12/31/2016

	Number of Samples	Level	Unit of Measure
Copper 90th Percentile	30	49.9	µ g/L
Lead 90th Percentile	30	3.05	µ g/L

This report is being sent due to revisions to the Lead and Copper Rule that require the Department of Natural Resources to report the lead and copper 90th percentiles to public water supply systems. Individual sample results are included in this mailing.

A level of 0 indicates that the 90th percentile was below the detection limits.

If the copper 90th percentile level is over 1300 micrograms per liter (µ g/L) or the lead 90th percentile level is over 15 micrograms per liter (µ g/L), your water system has exceeded the action level for one or both of these contaminants. No action is necessary unless action levels were exceeded.

October 25, 2016